

Intertek **CERTIFICATE**
FOR EUROPEAN PRODUCT SAFETY

Reference No. SE-S-2500591

Junction box

Type designation: Powerline wall box

Certificate holder: Pipelife Norge AS
Hamnesvegen 97
6650 Surnadal
NORWAY

The product complies with the standard(s): EN IEC 60670-1:2021 + A11

Date of expiry: 02 July, 2030

Additional information in Appendix

Certification Body: Intertek Semko AB, Product Certification **Place:** Kista - Stockholm

Signed: 
Anneli Averland Johansson **Date:** 02 July, 2025

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. This certificate is not issued under accreditation, by a non-approved body.

APPENDIX:

Reference No. SE-S-2500591

Technical Data:

Type designation	Powerline wall box
Trademark	Pipelife
IP-class	IP30
Test Report	2501863STO-001

Product information

The Powerline wall box has a standard size, with two different fronts. One for single and one for one and a half. The box is of grey insulation material with 8 inlets for $\varnothing$ 16mm pipes, 4 inlets for $\varnothing$ 20mm pipes, with locking spring, and 4 knock-outs on the bottom. Wall box intended for use in electrical installation with electrical conduit.

Manufacturing Sites:

Pipelife Norge AS
Hamnesvegen 97
6650 Surnadal
NORWAY

Certification Body:

Intertek Semko AB, Product Certification

Place: Kista - Stockholm

Signed:



Date: 02 July, 2025

Anneli Averland Johansson